

Zimbra

ctw6975@louisiana.edu

Daytime Fire Drills - Fall 2018**From :** Taz Wininger <taz@louisiana.edu>

Thu, Oct 04, 2018 05:01 PM

Subject : Daytime Fire Drills - Fall 2018**To :** Margarita Perez <mperez@louisiana.edu>, Greg Zerangue <gregz@louisiana.edu>, Larry Zerangue <ljz7577@louisiana.edu>, Joey Pons <safetyman@louisiana.edu>, Jules S. Breaux <jsb9113@louisiana.edu>, J. Collin Wynne <collin@louisiana.edu>, Roper Bethany - Building Manager, Housing Administration <C00025074@louisiana.edu>, Tanner Johnson <tlj4703@louisiana.edu>, Aldana Maylen - Dir, Dean of Students <C00244278@louisiana.edu>, Cruthirds Stephen A <sac3537@louisiana.edu>, Stephen C Williams <scw4875@louisiana.edu>, Steven J Hill <sjh9040@louisiana.edu>, Timothy D Hanks <tdh5555@louisiana.edu>**Cc :** Carol C Landry <cac8389@louisiana.edu>

Fire drills were conducted on 8/24/2018 at Agnes Edwards Hall and on 10/2/2018 at the Taft Site and the Rose Garden Site to satisfy our daytime fire drill requirement from the State Fire Marshal.

Those in attendance were: Taz Wininger, Stephen Cruthirds, Bethany Roper, and several Resident Assistants.

Taft Site (Baker & Huger Halls) - Alarms were set off at 1:00pm on 10/2/2018. Weather was sunny, bright and about 91 degrees.

Evacuation time at Baker took 4 minutes and Huger took 4 minutes (goal time at Baker and Huger). Approximate number of students evacuated totaled 425 (Baker-250 & Huger-175). Capacity of this site is 929. The panels were both clear with no troubles.

Comments: No one was observed using elevators at Baker by any students. Huger had 2 foreign students use the elevator. Stephen Cruthirds spoke to them about this. All residents exited the front door at Baker and were directed to Hamilton Hall parking lot near the Olivier Tower Parking garage, while Huger residents exited mostly from the rear door to the courtyard. This is in accordance with our BEAP, so no area of concern. Bethany Roper helped to direct all students to the correct areas within the parking lot perimeters. One resident was hearing impaired in the building, but was not present, (this was verified by

housekeeping). Buzzer was rang by housekeeping staff. RAs checked on disabled students, but none were observed in their rooms during the drill. All students followed direction from the attendance staff, as required. Assigned designated area for Taft Site is the Hamilton Hall rear parking lot area.

Rose Garden (Bonin, Coronna & Harris Halls) - Alarms were set off at 1:25pm on 10/2/2018. Weather was sunny and about 91 degrees.

Evacuation times at Bonin took 4 minutes, Coronna took the same amount of time and Bonin (goal time). Harris took 3 minutes (approximate goal time). Approximate number of students evacuated totaled 545 (Bonin-250, Coronna-250, & Harris-45).

Capacity of this site is 1,005. Panels were all clear with no troubles. Comments: All students followed direction from the attendance staff, as required. There were a few stragglers but mostly empty. This was a good drill and we have no concerns at this time. Assigned designated area for Rose Garden is the lawn space in front of the Student Union at Boucher St. and Hebrard Blvd. All students were directed on where to evacuate by RAs who were in attendance. Most students congregated across Boucher Street near the Student Union. RAs checked on disabled students, but none were observed in their rooms during the drill. There were no other issues noted during the drill.

Agnes Edwards Hall (previously the Conference Center) - Alarms were set off at 1:01pm on 8/14/2018. Weather was sunny and approximately 95 degrees. Evacuation time was 4 minutes. Approximate number of students evacuated totaled 220 (about 20 in lobby and all other were residents). Step labs had 2 employees that didn't evacuate. Capacity for this site is 497 (plus the students occupying the computer labs and offices). The assigned designated area for the Conference Center is the large sidewalks across Rex Street at Montgomery Hall. Comments: All students evacuated lab and common areas immediately. RAs checked on disabled students, but none were observed in their rooms during the drill. Troubles on the panel was fixed earlier that morning. It was all clear.

FIRE DRILL RESPONSE FORM

Note: This form should be completed for any scheduled Residence Hall Fire Drill and any false alarm which results in a building evacuation and scheduled or annual Fire Drills in the Academic Buildings. For help or questions regarding this form, call Taz Winger at 482-1049

Section 1: General Information

Building/Residence Hall Name: Taft Complex (Baker & Huger)

Date/Time Fire Drill Conducted: 1pm - 10/2/2018 (rescheduled)

Person Supervising the Fire Drill: Taz Winger & Stephen Cruthirds

Section 2: Alarm Information

Time of Alarm Activation: 1PM (am/pm)

Time of Alarm Silence: 1:04 (am/pm)

Did all Alarm Devices Activate? yes

Was there any trouble with the alarm, panel, or initiating devices?

—

Please describe any messages or codes shown on the panel, if any?

Section 3: Evacuation Information

Did everyone in the building evacuate? yes

Was corrective action taken for persons who did not evacuate? none detected

Was the evacuation orderly? yes

Any comments/recommendations

11B Resident Hearing Impaired - Buzzer Rang by Housekeeping Staff.
All residents exited the front door @ Baker + were directed to Hamilton Parking Lot. Huger Exited mostly from the rear door to courtyard.

Reference: UL Lafayette Environmental Health and Safety Policy, section 8.3.2

4 - Minutes Baker - 0 Elevator use.

PBPL @ Baker - 250

PPL @ Huger - 175

2 Foreign Students - Cruthirds

Bethany Roper
Cruthirds
Wiles

Sunny,
Bright.
91°

FIRE DRILL RESPONSE FORM

Note: This form should be completed for any scheduled Residence Hall Fire Drill and any false alarm which results in a building evacuation and scheduled or annual Fire Drills in the Academic Buildings. For help or questions regarding this form, call Taz Winger at 482-1049

Section 1: General Information

Building/Residence Hall Name: Rose Garden (Coronna, Bonin & Harris)

Date/Time Fire Drill Conducted: 1:30pm - 10/2/2018 (Rescheduled)

Person Supervising the Fire Drill: Taz Winger & Stephen Cruthirds

Section 2: Alarm Information

Time of Alarm Activation: 1:30³⁵PM (am/pm)

Time of Alarm Silence: 1:29 (am/pm)

Did all Alarm Devices Activate? yes 4min

Was there any trouble with the alarm, panel, or initiating devices?

no

Cruthirds
miles
1 RA to Count
(a few stragglers
but mostly empty)

Please describe any messages or codes shown on the panel, if any?

No troubles

Section 3: Evacuation Information

Did everyone in the building evacuate? yes

Was corrective action taken for persons who did not evacuate? _____

Was the evacuation orderly? yes

Any comments/recommendations Students were not too happy -

But no disrespect

Reference: UL Lafayette Environmental Health and Safety Policy, section 8.32

HARRIS - 3min - 45 ppl
Coronna - 4min - 250
Bonin - 4min - 250 } estimation

FIRE DRILL RESPONSE FORM

Note: This form should be completed for any scheduled Residence Hall Fire Drill and any false alarm which results in a building evacuation and scheduled or annual Fire Drills in the Academic Buildings. For help or questions regarding this form, call Taz Wininger at 482-1049

Section 1: General Information

Building/Residence Hall Name: Conference Center
Date/Time Fire Drill Conducted: 8/14/2018 1pm
Person Supervising the Fire Drill: Carl Taz Wininger

Section 2: Alarm Information

Time of Alarm Activation: 1pm (am/pm) (1:01 ACTUAL)

Time of Alarm Silence: 1:05pm (am/pm) (1:05 ACTUAL)

Did all Alarm Devices Activate? yes

Was there any trouble with the alarm, panel, or initiating devices?

Troubles on the panel were fixed earlier
That morning. It was all clear.

Please describe any messages or codes shown on the panel, if any?

Section 3: Evacuation Information

Did everyone in the building evacuate? Yes

Was corrective action taken for persons who did not evacuate? N/A

Was the evacuation orderly? Yes

Any comments/recommendations 200 ppl about 95° - Sunny

Financial Aid - about 20 (in lobby) - all others Residents

Step Labs had 2 employees that didn't Evac